



- Andrija Štampar Teaching Institute of Public Health is certified by the Bureau Veritas Croatia in accordance with ISO 9001 (CRO 19561Q/01) and ISO 14001 (CRO 19079E/01) of 14 May 2014. In July 2016, Andrija Štampar Teaching Institute of Public Health obtained OHSAS 18001 (CRO20199S) certificate.
- Reference Center of the Ministry of Health for Food Health Safety Analysis; UP/I-510-01/15-01/31; Reg. No: 534-04-1-2/7-16-14 of 14 July 2016.
- Official laboratory pursuant to the Decision of the Ministry of Agriculture for sampling and testing food and foodstuffs for animals, testing natural mineral, table and spring water, Class: UP/I-322-01/16-01/59, Reg. No: 525-10/1308-17-5 of 7 February 2017.

TEST REPORT

For analytic number: 05206 00032/19

Buyer AIR RIO
51550 Mali Lošinj, Dražica 15

Date: 23 July 2019

GENERAL INFORMATION

Class: 351-04/19-03/37
Reg. No 381-5-3/2-19-04

Sample name: **AIRBREATH OXYGEN**
Sample type: Indoor air
Time of delivery: 19 July 2019, 11:46 a.m.
Analysis started: 19 July 2019, 11:46 a.m. Analysis completed: 22 July 2019, 12:01 noon
Location: AIR RIO, Dražica 15, Mali Lošinj
Analysis type: Microbiological air analysis
Reason for the request: Health safety
Delivery type: Sampled
Sampled: Per party

Owner: AIR RIO
Dražica 15, 51550 Mali Lošinj, Croatia

User: AIR RIO
Dražica 15, 51550 Mali Lošinj, Croatia

Deliver to: 1. AIR RIO, Croatia, 51550 Mali Lošinj, Dražica 15

The results refer exclusively to the analyzed sample and may not be used for advertising purposes. Facsimile is authentic to the original signature of an authorized person.

DECLARATION OF CONFORMITY:

In accordance with the Portugal standard "Diario da Republica n.º 235/2013, 1º Suplemento, Serie I de 2013-12-04", the measured values of the total number of bacteria and mold in the sample do not exceed the reference value.

Head of Laboratory
M.Sc. Ivona Majić, graduate engineer



The results refer exclusively to the analyzed sample and may not be used for advertising purposes. Facsimile is authentic to the original signature of an authorized person.

RC* Recommended criterium

Date: 23 July 2019

Buyer: AIR RIO, 51550 Mali Lošinj, Dražica 15

Sample name: AIRBREATH OXYGEN

Time of delivery of the sample to the laboratory: 19 July 2019, 11:46 a.m.

TEST RESULTS

For analytic number: 05206 00032/19

Laboratory for microbiological air analyses					
Analysis started: 19 July 2019, 11:46 a.m.			Analysis completed: 22 July 2019, 12:01 noon		
Analysis name	Method	Testing technique	Unit of measurement	Result	RC*
aerobic mesophilic bacteria	HRN EN 13098:2008	cultivation	cfu m ⁻³	< 1	
mold	ISO 16000-17:2011	cultivation	cfu m ⁻³	< 1	
Sampling ISO 16000-18:2011:		impakcija			
In accordance with the Portugal standard "Diario da Republica n.º 235/2013, 1º Suplemento, Serie I de 2013-12-04", the measured values of the total number of bacteria and mold in the sample do not exceed the reference value.					

Head of Laboratory
M.Sc. Ivona Majić, graduate engineer



End of testing report